

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. MEMO/2025

Dated:25/04/2025

It is certified that an inspection team headed by M.K. SINGH MEDICAL OFFICER , (Name of Officers with designation) from PHC ,RUDAULI , AYODHYA (Name of Department/ Office) inspected the **GLOBAL PUBLIC SCHOOL** SHAHBAJPUR , AKHTIYARPUR, AYODHYA ,(Name &Address of the school)on24/04/2025 (date of inspection)and found that the **GLOBAL PUBLIC SCHOOL** .(Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt

The above is valid for a period of ONE YEAR

Signature with Seal: ...

M.K. Singh
25/4/2025
MEDICAL OFFICER
PHC , RUDAULI,
AYODHYA.

Name: M.K. SINGH

Designation : MEDICAL OFFICER

Name & Address of the Office / Department : PHC,RUDAULI,
AYODHAYA

To
MANAGER
GLOBAL PUBLIC SCHOOL
SHAHBAJPUR , AKHTIYARPUR,
AYODHYA
(Name&AddressoftheInstitution)

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.MEMO/2025

Dated: 15/04/2025

It is certified that an inspection team headed by MAYANK SINGH (CHEMIST)

(Name of Officers with designation) from 14/04/2025 PHED

inspected the **GLOBAL PUBLIC SCHOOL**, SHAHBAJPUR , AKHTIYARPUR, AYODHYA

(Name & Address of the school) on 14/04/2025.(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. LK/20015/2025 dated 14/04/2025

of JAL ANUSANDHAN KENDRA LUCKNOW PHED Lab) certified that

the **GLOBAL PUBLIC SCHOOL** (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ONE YEAR

Signature with Seal:


EXECUTIVE ENGINEER
JAL ANUSANDHAN KENDRA
LUCKNOW
15/04/2025


Name
Designation

K.P. RAM
EXECUTIVE ENGINEER

To
MANAGER
GLOBAL PUBLIC SCHOOL
SHAHBAJPUR , AKHTIYARPUR, AYODHYA
(Name & Address of the Institution)

Name & Address of the Office / Department JAL
ANUSANDHAN
KENDRA LUCKNOW

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



जल अनुसंधान केंद्र लखनऊ

सेक्टर न्यू अलीगंज लखनऊ

TEST CERTIFICATE

Test Report No : MEMO/2025
Sample Name : Borewell Water
Sample Code : 20015
Issued To : GLOBAL PUBLIC SCHOOL
SHAHBAJPUR, AKHTIYARPUR, AYODHYA


Issue Date : 15/04/2025
Sample Received On : 14/04/2025
Reference No : NA
Sampling Date : 14/04/2025
Sampling Quantity : 1.5 ltr
Batch No /Lot No : NA
Date of Mfg : NS
Date of Exp. : NS
Date of Starting : 15/04/2025
Date of Completion : 15/04/2025


Sample Submitted By : DEEPAK SINGH
Mfg By : NA
Sample Description : Physical & Microbiological Analysis of water sample
Location : Mix Water

S.No.	Test Parameter	Units	Results	Specification as per IS:10500:2012		Test Method
				Acceptable Limit	Permissible Limit	
1	Color	Hazen	1	5 max.	15 max.	IS 3025(P-4)
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025(P-5)
3	Turbidity	NTU	0.2	1 max.	5 max.	IS 3025(P-10)
4	pH value at 25°C	-	7.85	6.5-8.5	No Relaxation	IS 3025(P-11)
5	Total Hardness as CaCO ₃	mg/l	865	200 max.	600 max.	IS 3025(P-21)
6	Calcium (as Ca)	mg/l	188.4	75 max.	200 max.	IS 3025(P-40)
7	Iron (as Fe)	mg/l	0.032	1 max.	-	IS 3025(P-53)
8	Magnesium (as Mg)	mg/l	96.0	30 max.	100 max.	IS 3025(P-46)
9	Chloride (as Cl)	mg/l	1159.6	250 max.	1000 max.	IS 3025(P-32)
10	Free Residual Chlorine	mg/l	Nil	0.2 max.	1 Max.	IS 3025(P-26)
11	Sulphates (as SO ₄)	mg/l	518.5	200 max.	400 max.	IS 3025(P-24)
12	Total Alkalinity (as CaCO ₃)	mg/l	184	200 max.	600 max.	IS 3025(P-23)
13	Fluoride (as F)	mg/l	0.038	1 max.	1.5 max.	IS 3025(P-60)
14	Total Dissolved Solid (TDS)	mg/l	2998	500 max.	2000 max.	IS 3025(P-16)
15	Total Coliform	MPN/100 ml	Absent	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	IS 1622
16	E.coli	MPN/100 ml	Absent	Shall not be detectable in any	Shall not be detectable in any	IS 1622

SAMPLE COLLECTED BY US

End of Report


JAL ANUSANDHAN KENDRA
LUCKNOW
Authorized By (Sign & Stamp):


EX-ENGINEER 15/04/2025
JAL ANUSANDHAN KENDRA
LUCKNOW
Approved By (Sign & Stamp):